



1




Turn off the general switch

2




Create a CutOut

3




Expose wires

4




Connect wires

5




Put it in place
by pressing the light upwards

6



Turn on the general switch

7



Max TA 30°



- A. The installation must be done by competent electricians.
- B. Product can not be modified
- C. Make sure the power has been switched off before installation
- D. The product is a Class III luminaire and shall be connected with a constant 350mA driver.
- E. The connection of the luminaire should be standard with 0.5mm²-1.5mm² conductor.
- F. The specification for the driver means determines on the voltage and the maximum number of luminaires per loop
- G. Power should never be regulated on the secondary side
- H. See the installations on the image
- I. Note that the maximum allowed TA temperature is 30

